



Timber Research and Development Institute Praha
Na Florenci 7-9, 111 71 Praha 1, Czech Republic

issues to the applicant:

KIM GIA TRADING AND MANUFACTURING JSC
Southern Industrial Park
Van Phu Commune
Yen Bai City, Yen Bai Province Vietnam

plant: KIM GIA TRADING AND MANUFACTURING JSC, Southern Industrial Park,
Van Phu Commune, Yen Bai City, Yen Bai Province Vietnam

CERTIFICATE

No.: 3653/22

for the product

PLYWOOD FOR INTERNAL USE AS A NON-STRUCTURAL COMPONENT IN DRY CONDITIONS (Type EN 636-1)

Prescriptions specifying the features of product:

ČSN EN 636+A1 Plywood – Specification

This certificate confirms that the product mentioned above was tested according to EN 717-1, EN 310, EN 314-1,2 and according to result values was classified:

Formaldehyde release - emission class E1

Bending strength – F 25/25


Modulus of elasticity in bending – E 50/50

Bonding quality - bonding class 1 (dry environment)

This certificate is issued on the basis of Test report No. MVZ-A-2022-002546 from 2022-11-29 and Test report No. MVZ-A-2022-002559 from 2022-12-06.

The validity of this certificate is limited for 3 years, i.e. till 2025-12-16. This certificate will be deprived of validity if the conditions occurred due to changes do not correspond to those on which they were granted.

The applicant may enclose the document evidencing the conformity to the products, which are conformable to the certified one.



Jitka Beránková
Ing. Jitka Beránková, Ph.D.
Head of certification department

Prague, 2022-12-16

